

MULTIPLE FAN BLOWER DOOR TESTING - LESSONS LEARNED

Presented by: Mike Barcik & Bourke Reeve, Southface
mikeb@southface.org breeve@southface.org



www.southface.org



<https://vimeo.com/169382048/c973625071>

Photo: Jonathan Hillyer, 2009

COURSE DESCRIPTION & LEARNING OBJECTIVES

Southface's multi-year study of small commercial buildings' energy and water consumption includes a study of building air leakage testing. Learn the details of how the testing was performed, how the results were normalized and how the various buildings stacked up. Also, discover and utilize the various templates and toolkits to add multiple fan testing to your arsenal.

- Understand the ACBI program & the Southface process for researching small commercial buildings
- Learn to apply multiple fan BD testing to small commercial projects – grasp the differences compared to testing homes
- Analyze test results and learn from interesting BD videos
- Take advantage of the free Multiple Fan BD Toolkit Resources




OVERVIEW OF PRESENTATION

- Why small commercial?
- ACBI Overview
- Southface's approach
- A few lessons learned
- Multiple Fan BD testing
- Cool BD videos
- Lessons learned from testing ~50 small commercial buildings
- New free Toolkit resources




WHY SMALL COMMERCIAL? ($\leq 50K$ SF)



AUDITORS & HERS RATERS - SMALL COMMERCIAL


- New market
- Building characteristics
- Systems
- Processes
- Who else is serving this market?



Advanced Energy Design Guidelines

SMALL COMMERCIAL ENERGY CONSUMPTION

What is the biggest use of energy in small commercial buildings?



ADVANCED COMMERCIAL BUILDINGS INITIATIVE

Research



Demonstrate



Deploy



PARTNERSHIPS




SOUTHFACE APPROACH

20% improvement over existing

1. Benchmark
2. Assessment
3. Analysis
4. Recommendations & Projected Savings
5. Bids & Implementation
6. Verify
7. Ongoing support



BENCHMARK – ENERGY STAR PORTFOLIO MANAGER (ESPM)



ASSESSMENT & ANALYSIS



M11

T12 - 2L - 4' - 40W

LIGHTING SURVEY		Current					Notes	
Fixture Code	Fixture Name	Area Code	Fixture Code	Fixture Qty	Controls Code	Sensor Qty		Lamps Out
1	T12 - 1L - 2' - 20W		22	57	2	1	1	0
2	T12 - 2L - 2' - 20W		22	63	1	1	1	2
3	T12 - 1L - 4' - 34W		26	16	1	1	1	1
4	T12 - 2L - 4' - 34W		15	4	6	1	1	0
5	T12 - 3L - 4' - 34W		13	11	1	1	1	0
6	T12 - 4L - 4' - 34W		13	27	1	1	1	0
7	T12 - 2L - 4' - 40W		4	29	1	1	1	0
8	T12 - 2L - 4' - 40W		13	16	1	1	1	0
9	T12 - 4L - 4' - 40W		1	12	4	1	1	1
10	T12 U - 2L - 40W		20	18	3	1	1	1
11	T12 - 1L - 8' - 60W		20	20	2	1	1	1
12	T12 - 2L - 8' - 60W		18	27	2	1	1	0
13	T8 - 1L - 2' - 17W		18	26	1	1	1	0
14	T8 - 2L - 2' - 17W							
15	T8 - 1L - 4' - 32W							
16	T8 - 2L - 4' - 32W							
17	T8 - 3L - 4' - 32W							
18	T8 - 4L - 4' - 32W							
19	T8 - 1L - 8' - 59W							
20	T8 - 2L - 8' - 59W							
21	T8 U - 1L - 82W							
22	T8 U - 2L - 82W							
23	T5 - 1L - 4' - 54W							

Introduction

Utility Analysis

End Use Breakdown

Recommendations

Summary

Lighting

RECOMMENDATIONS

Energy Projects (7)

Name	Date Implemented	Estimated Savings
Domestic hot water loop timer	12/31/2014	\$175
High-efficiency appliances	12/31/2014	\$4,921
Install vending machine controls	12/31/2014	\$161
LED lighting & lighting controls	11/20/2014	\$6,875
Low-flow plumbing fixtures	9/30/2014	\$344
Remove old appliance	9/1/2014	\$105
Upgrade HVAC controls	10/24/2014	\$4,204

Total Project Investment


\$78,681.00

Total Estimated Savings

\$16,785.00



PRESENTATION & REPORT



Executive Summary	
Next Steps	
Building Assessment Overview	
Facility Background	
Energy & Water Overview	
Energy & Water Consumption History	
Annual Energy and Water Use Breakout	
Building Envelope	
Lighting	
Plumbing Fixtures	
Domestic Hot Water	
Appliances & Plug Loads	
Heating, Ventilation, and Air Conditioning (HVAC)	
Energy & Water Efficiency Projects	
Project Discussion	
No-Cost and Low-Cost Recommendations	
Other Sustainability Recommendations	
Appendix A: Project Assumptions	
Appendix B: Lighting Efficiency Retrofit Details – Proposed Lighting and Lighting Controls	
Appendix C: Georgia Power Rebate Program	
Appendix D: Project Implementation Verification Checklist	



BIDS, IMPLEMENTATION & VERIFICATION

1. ENERGY STAR Water Heater

- ☐ ENERGY STAR Tankless Water Heater minimum efficiency rating at or above 93% with combustion air inlet and exhaust piping fully ducted to exterior
- ☐ Activation flow rate at or below lowest flow water fixture (0.5 GPM)
- ☐ Water temperature max 125°F
- ☐ Accessible hot water lines insulated to min R-4

2. Bathroom Efficiency

- ☐ Bathroom sinks and hand sink in kitchen (4 sinks total), faucets are WaterSense labeled with maximum flow rate of 0.5 GPM
- ☐ Shower heads (2 heads total) are WaterSense labeled with maximum flow rate of 2.5 GPM or less
- ☐ Toilets (3 toilets total) are si
- ☐ Urinal (1 urinal total) is Wat

Performance Comparison

3. Kitchen Efficiency

- ☐ ENERGY STAR Commercial R
- ☐ ENERGY STAR Residential Re
- ☐ ENERGY STAR Commercial D
- ☐ Kitchen faucets (up to 2 fau
- ☐ Pre-rinse spray valves (up to

	Year Ending 12/31/2014 (Baseline)	Year Ending 7/31/2015 (Selected)	% Change	Property's Target	National Median	ENERGY STAR Score of 75
ENERGY STAR Score	N/A	N/A	N/A	N/A	50	75
Energy						
Site EUI (kBtu/ft²)	60.1	40.5	-32.5	48.1	49.9	N/A
Source EUI (kBtu/ft²)	170.6	114.8	-32.7	136.5	141.4	N/A
\$	37,444.33	28,032.45	-25.14	29,955.46	34,525.86	N/A
\$/ft²	2.16	1.62	-25.14	1.73	1.99	N/A
Greenhouse Gas Emissions						
Metric Tons CO2e/year	169.3	114	-32.66	135.5	140.4	N/A
kgCO2e/ ft2/year	9.8	6.6	-32.66	7.8	8.1	N/A



LESSONS LEARNED – LIGHT COMMERCIAL

- Commercial Buildings are Systems Too!
 - Subcontractors and repair persons only know what they know
 - “Sprinkler pipes could freeze – better heat the vented attic!”
- Occupants aren’t “Owner” of commercial spaces
 - Turn things off? – not my job!
 - “Maybe it’s supposed to be on...”
- No feedback
 - Accountant pays utility bills but doesn’t share cost implications with others
- Landlord focus is on complaints
 - Often, doesn’t care about utilities
- Designers still old school –
 - Cheap first cost rules



Light commercial projects typically don't have facility staff!



PROGRAM LESSONS LEARNED


- Utility rate structures/rebates matter
- Equipment left on when unoccupied
- Combustion safety
- LED upgrades
 - New LED fixture
 - Keep fixture housing + LED "guts"
 - Swap LED tubes (ballasts)
- Vending machines
- Hot water
- Sprinkler piping
- Implementation \neq job complete
 - Top down support & education
 - Verification
- Ventilation

Lessons Learned
recognize mistakes
observe what works
document them
share them



TYPES OF BLOWER DOOR TESTING

- Single Point
- Multipoint
- Multi-Family
 - Unguarded
 - Guarded
- Multiple Fan




MULTIPOINT BLOWER DOOR TEST

An automated **Multipoint Blower Door (MBD)** Test may be performed using a laptop, software, and a BD fan controller

In a *MBD test*, the building's actual CFM_{xx} is determined at different pressures


The results can be plotted to measure the infiltration at any given pressure – providing more accuracy than a single point test

In theory, this approach reduces error and provides an acceptably accurate measurement of duct leakage via subtraction method




MULTIFAMILY BLOWER DOOR TESTING

- Multi-Family
 - Unguarded
 - Guarded



MULTIFAMILY BLOWER DOOR TESTING


- Southface results for MF testing for five projects from 1998-2001
 - Unguarded to Guarded Reduction Range
 - Typical to find “a couple hundred cfm50” across units



Project	Units Tested	Reduction Range	Outliers
'98 Augusta	1	(30%)	
'99 Alexander City	10	(0-18%)	
'00 Sylacauga	9	(11-32%)	48%, 59%
'00 Tallahassee	16	(0-5%)	23%, 26%
'01 Ozark	8	(0-11%)	

MAPLEWOOD PARK

Research to obtain real test data for ORNL's MULTEA numerical model




MAPLEWOOD PARK


Three different unit types:



1,040 sq.ft



1,135 sq.ft



1,126 sq.ft



GUARDED VS. UNGUARDED



Vs.



TYPICALLY...


Unguarded – A single point infiltration test measures dwelling unit air leakage one time at single reference pressure (50 pa) using a single blower door fan.



 Southface


HOWEVER...

Guarded – A guarded test measures dwelling unit air leakage at a reference pressure while inducing the same reference pressure to adjacent dwelling units through the use of multiple blower door fans



 Southface

HOW DID WE DO THIS?



Breezeway



High tech bucket



2 of 5 Blower Doors


RESULTS: MAPLEWOOD PARK

Wing 1 CFM50				Wing 2 CFM50			
Unit	Unguarded	Guarded	Difference (%Unguarded)	Unit	Unguarded	Guarded	Difference (%Unguarded)
1	1628	1445	183 (11.2%)	6	1400	1304	96 (6.9%)
2	1435	1101	334 (23.3%)	7	1250	1015	235 (18.8%)
3	1718	1400	318 (18.5%)	8	1275	1027	248 (19.5%)
4	1104	1027	77 (7%)	9	1223	1132	91 (7.4%)
5	1544	1458	86 (5.6%)	10	1225	1149	76 (6.2%)
Total	7429	6431	998 (15.5%)	Total	6373	5627	746 (11.7%)

Top units were tightest!




COMPARTMENTALIZATION

- Some commercial buildings do not openly connect / communicate throughout
 - Different compartments may have different leakage
 - Individually control each BD
 - Designate one BD zone as “master” and others as “submissives” and control all BD’s to maintain consistent pressure between zones



COMPARTMENTALIZATION


- Five distinct compartments



CODES AND PROGRAMS LEAKAGE REQUIREMENTS

Air Leakage Testing

- GSA – new buildings
- Washington – >5 stories
- US Army Corps – new buildings and major renovations
- ASHRAE 189.1
- LEED BD+C
- EarthCraft Light Commercial
- IECC 2012 & beyond



MULTI-FAN BLOWER DOOR TESTING - AN EXCELLENT RESOURCE

<http://support.energyconservatory.com/hc/en-us/articles/202478994-Beyond-Residential>

- Explains both theory and application
- Great websites, videos and training information from both:
 - Retrotec
 - Energy Conservatory

Blower Door Applications Guide: Beyond Single Family Residential

By Terry Brennan and Mike Clarkin of Camroden Associates
And
Gary Nelson, Collin Olson and Paul Morin of The Energy Conservatory



BIG PICTURE TEST PROCESS

- Follow a protocol
- Map equipment location
- Pre-test planning meeting of all participants – assign roles/stations
- Gather all equipment – confirm that it works
- Arrive, install equipment & prep building for testing
- Use software to perform testing
- Diagnose leaks and document results



BD TESTING COMMERCIAL BUILDINGS

- Address compartmentalization and guarded/unguarded issues
- Configure hardware and run software
- Prompts
 - for baseline(s)
 - for data recording periods
- Graphs results




MULTI-POINT CURVE FIT – CONFUSING RESULTS

- ASTM Standard E779-03³: multi point test from ± 20 Pa to ± 75 Pa


Power Law equation: $Q = C * \Delta P^n$

- Q – infiltration rate
- C – flow coefficient
- ΔP – pressure difference across envelope
- n – flow exponent



A BETTER WAY TO PLOT THE RESULTS

- Data becomes easier to read when plotted on logarithmic scale
- Curve allows leakage estimation at any pressure (e.g. 4 Pa)



ELR₇₅ – A BETTER METRIC

Envelope Leakage
Ratio @ 75 Pa
(CFM₇₅ / shell area)

- Leakage occurs through skin of building (not through volume)
- Normalizing leakage at 75Pa (0.3 in w.c.) based on shell area is most common for commercial buildings

Example Calculation

A 1,280 square foot building has an SFBE of 3,224 square feet and a measured fan flow of 1,483 at CFM₇₅. Determine the Envelope Leakage Ratio at 75 Pa by dividing the cubic feet per minute of air volume moved through the fan by the total square footage of the building thermal envelope.

Top Flat Ceiling Area

$$20' \times 34' = 680ft^2$$

Building Envelope Floor Area (includes shaded area)

$$20' \times 30' + 20' \times 4' = 680ft^2$$

Gross Exterior Insulated Wall Area = 1,864ft²

$$\text{1st Floor: } (20' + 30' + 20' + 30') \times 10' = 1,000ft^2$$

$$\text{2nd Floor: } (20' + 34' + 20' + 34') \times 8' = 864ft^2$$


$$SFBE = 680ft^2 + 680ft^2 + 1864ft^2 = 3,224ft^2$$

$$\text{Fan Flow Measurement} = 1,483 \text{ CFM}_{75}$$

$$ELR_{75} = \frac{CFM_{75}}{SFBE}$$

$$ELR_{75} = \frac{1,483 \text{ CFM}_{75}}{3,224 \text{ sf}}$$

$$ELR_{75} = 0.46 \text{ Envelope Passes}$$



PREDICTING LEAKAGE?

Is there a Leakage Correlation based on:

- Age / Code in place? Size? Usage type? Construction Materials?

What is baseline & expected range for a standard building in the southeast?

Was there anything predictable?

- Corrugated metal roof connections
- Junctions of two different planes (e.g., roof to wall)
- Junctions of different materials (e.g., metal or wood to block or drywall)
- Hidden pathways (e.g., above the drop ceiling tiles)
- Enforcement of code fire blocking



- Utility Chases
- Metal Roof Decking
- Gabled Roof Junctions
- Mechanical RTU Penetrations
- Roof Membrane Connections

BD REVEALS COMMON LEAKAGE PATHWAYS



UTILITY CHASE



METAL BUILDING ROOF




Shims



Roof above shims

GABLED ROOF



RTU LEAKAGE



 Southface

FLAT ROOFED STRIP MALL



 Southface

PARAPET LEAK



 Southface

HOW TO GET FOG IN THE RIGHT PLACE




 Southface

INFLATED TPO MEMBRANE



 Southface

DETAILS




 Southface

ORIGINAL 12 BUILDINGS

Test Buildings	Date of Test	Cond. Floor Area (s.f.)	SFBE	# of Stories	ELR75	Depressurization @-75Pa (masked)	Pressurization @+75Pa (masked)
	7/17/2014	17,283	48,330	1	0.240	11,602	12,355
	7/30/2014	2,318	9,775	1	0.141	1,378	1,366
	6/19/2014	3,533	12,437	2	0.189	2,353	2,674
	8/6/2014	5,946	11,637	3	0.167	1,938	2,331
	9/16/2014	12,864	36,845	1	0.456	16,794	20,319
	5/20/2014	11,117	29,008	3	0.461	13,365	14,234
	5/15/2014	17,176	41,635	1	0.560	23,322	23,539
	4/10/2014	5,910	15,422	1	0.702	10,823	9392**
	6/10/2014	34,200	69,600	2	0.887	61,751	74,721
	10/10/2014	34,200	69,600	2	0.578	40,212	44,683
	5/28/2014	3,035	8,804	1	1.277	11,245	12,154
	11/22/2014	3,035	8,804	1	1.412	12,428	12,422
	6/19/2014	7,912	20,956	1	0.423	8,854	9,234
	7/15/2014	5,020	15,402	2	1.438	22,151	22,308

ORIGINAL 12 BUILDINGS



ANALYZING TESTING RESULTS

- All buildings are created unequal – no apparent correlation between age, type of construction, location, etc.
- Air Sealing – starts at design
- Existing buildings – can be retro sealed
- Designed air barrier – 0.25 ELR₇₅; (average existing 0.84 – over 3 times leakier!)
- Modeling tools vary significantly in predicted savings from air sealing – approximately ~10%




ADDITIONAL BUILDINGS – SIMILAR RESULTS


Test Buildings	Date of Test	Cond. Floor Area (s.f.)	SFBE	# of Stories	ELR75	Depressurization @ -75Pa (masked)	Pressurization @ +75Pa (masked)
	11/11/2014	4,261	13,219	1	0.429	5,666	5,518
	11/17/2014	6,692	16,829	2	1.201	20,214	19,589
	12/4/2014	2,128	5,760	1	0.623	3,587	3,628
	12/10/2014	1,081	3,562	1	0.626	2,230	2,269
	12/15/2014	1,480	5,480	1	0.562	3,081	3,501
	12/16/2014	2,207	8,878	1	0.750	6,662	6,745
	12/17/2014	1,586	6,743	1	0.761	5,134	5,134
	12/18/2014	1,895	7,907	1	0.737	5,825	5,662
	12/19/2014	1,561	6,674	1	0.330	2,200	2,181
	1/14/2015	12,142	32,873	1	0.639	21,020	22,286
	2/4/2015	3,416	9,336	1	0.493	4,601	4,672
	2/9/2015	4,236	10,390	1	0.500	5,195	5,194
	11/12/2015	11,417	20,297	3	0.184	3,740	4,738
	1/11/2016	3,020	8,123	1	0.517	4,200	4,553
	1/12/2016	4,315	14,359	1	1.028	14,758	16,428
	1/13/2016	3,900	12,000	1	1.244	14,933	15,513
	8/22/2012	21,628	44,259	2	0.339	15,019	n/a
	5/22/2014	11,202	37,370	1	0.188	7,030	n/a
	6/11/2014	1,634	4,847	2	0.394	1,910	2,352
	6/11/2014	500	2,545	1	0.251	638	791
	7/10/2014	6,082	13,937	1	1.021	14,224	
	7/29/2014	4,615	11,165	1	1.296	14,467	15,824
	8/4/2014	4,615	14,668	1	0.581	8,515	
	8/18/2014	4,615	14,668	1	0.422	6,192	6,402
	8/26/2014	1,135	3,949	1	0.313	1,238	
	8/26/2014	1,680	6,409	1	0.360	2,310	
	10/2/2014	1,135	3,949	1	0.13	514	
	10/2/2014	1,680	6,409	1	0.12	798	



ADDITIONAL BUILDINGS – SIMILAR RESULTS



AIR SEALING RETROFITS



Air leakage of existing buildings can be substantially reduced with **spray foam**

ENERGY MODELING CHALLENGES

- Commercial building air leakage testing is in its infancy (<400 buildings in largest known database); modeling default values are **unsubstantiated**
- Input for modeling software varies: ACH_{nat} , ACH_{50} , cfm/ft² of floor area, **cfm₄/ft² of envelope area @ 4 Pa (ELR₄)**
- Testing is conducted at accelerated pressures to minimize other driving forces – must extrapolate from multipoint regression analysis



TESTING PROCEDURE LESSONS LEARNED

- Get floor plans or at least get fire evacuation plan
- Consider a SketchUp model for more cut-up assemblies and to assist in take-off calculations
- Pre meeting – assign tasks and zone responsibilities
- Written test procedure
- Site communication – local contact
 - Signage around building
 - Walkie-talkies
 - Pre-condition of thermostat settings



TESTING PROCEDURE LESSONS LEARNED, CONT.

- Reinforce masking
- Foam insulation tubes / pool noodles at doors with auto closers; door shims
- 1 fan per circuit
- Extension cords, power indicators, long tubing
- Theatrical fog machine, fan, flex duct and pole
- Duplicate fans (if possible, face in alternate directions)
- Ladders, extension cords, batteries, extra kits if available



HOW TO ESTIMATE NUMBER OF FANS

- Minimum one per "compartment"
- Estimate an ELR₇₅
 - Determine shell area
 - Back out CFM₇₅
- Assume ~5,000 cfm per fan plus one extra fan




- Example: 40' x 60' x 25' building
 - Shell Area: 9800 s.f. (Ceiling: 2400 s.f., Floor 2400 s.f., Walls: 5000 s.f.)
 - Assume leaky ELR₇₅ = 1.5 = CFM₇₅ / 9800 so CFM₇₅ = 14,700
 - 14,700 / 5000 = 2.9 which rounds to 3 and then add 1 for **4 BD's total**



PRESSURIZATION - FANS NEED REF TUBE

The blower door fan pressure is always measured at the flow sensor WRT the **fan inlet side**:

- the building when depressurizing
- the outside when pressurizing – use reference tube



SOUTHFACE RESOURCES – ONE PAGE TEST SHEET

Multi-fan multi-point testing

- Test protocol
- Paper copy is great for results tracking while performing testing
- Spreadsheet version can perform calculations



ECLC Envelope Tightness Testing Procedure v1.0	
Oak Brook 630 East Lake Dr, Decatur, GA 30030 Date of Testing: 1/12/2016 m-d-y Participants: Christine, Miles, Alex, Rachel Building Conditioned Floor Area: 43,151 sq ft Building Shell Area (SBA): 143,359 sq ft Outdoor Temperature at Start: 50.0 °F Indoor Temperature at Start: 50.0 °F Elevation of project: 500 ft Basic Description of Building (e.g., type of occupancy, number of stories, wall, roof and foundation assembly type, orientation, etc.): CMU walls, metal roof trusses flat roof, FRU serves whole building, adjacent space is church All designated team members perform set-up as assigned. Apply masking to all Outside Air (OA), Make-Up Air (MUA), and Exhaust and Dryers (EDH) fans but do not seal flue! Perform Pre-Depressurization Baseline for 2 minutes (all fans covered) Depressurize building to -75 Pa and record single point result During single point testing, team should check for leaks in designated areas while BO's are operating. Document discovered leaks and/or building issues. Perform zone press USACE and ECLC Depressurization Multi-point Test Continue depressurization from -75 Pa to -100 Pa, adjusting fans for every 5 Pa interval *If Building Baseline pressure exceeds +/- 5 Pa, adjust range of test pressures. (Example, if Baseline is -30 Pa (last data point) is recorded, cover all fans and perform post-baseline for 120 seconds Enter multi-point Depressurization curve fit value @ -75 Pa. [Curve fit data shall have an R^2 > 0.98 for valid test] Reverse fans and add fan pressure reference tube(s) Perform Pressurization to single point @ +75 Pa USACE Pressurization - With fans covered, perform pre-pressurization baseline for 120 s. THIS IS OPTIONAL TESTING During pressurization testing, fog machine leak identification can be performed USACE Pressurization (enter multi-point curve fit value @ +75 Pa) THIS IS OPTIONAL TESTING The building pressure will be ramped down every 5 Pa intervals. After +20 Pa is recorded, cover all fans and perform post-baseline for 120 seconds. Fan curve fit value for -50 Pa (for comparison) Fan curve fit value for +50 Pa (for comparison) With fans kept in pressurization mode, remove mask from OA (and hood MUA, if applicable). Record single point test value @ +50Pa Turn fans around and setup for depressurization mode (OA+MUA unmasked). Record single point test value @ -50Pa Keep fans in the same configuration (depressurization mode). Remove mask from exhaust fanhood. Record single point test value @ -50Pa Cover all EDH fans and keep all fans off. Remove mask from kitchen hood (if applicable). Record building baseline pressure for two 30 second periods Turn on all air handlers. Record building pressure for two 30 second periods With air handlers running, turn on all exhaust fans. Record building pressure for two 30 second periods If a kitchen hood is present, turn it on. With air handlers + all exhaust fans + hood on, record building pressure for two 30 second periods Record building baseline pressure for two 30 second periods Outdoor Temperature at Finish: 50.0 °F Indoor Temperature at Finish: 50.0 °F Description of weather conditions during testing: Sunny clear, cold from night	Testing should not be performed if: Δ Temp Difference X Height > 1180 Example, 30 °F x 40' = 1,200 (so do not test) If Building Baseline Pressure exceeds +/- 5 Pa, then adjust pressure testing interval (*see below)

SOUTHFACE RESOURCES

- Assessment toolkit
 - Process
 - Data collection
 - Analysis
 - Report template
 - Implementation checklist
- Quick guides
 - Fire stations
 - Rec centers
 - Small commercial on campus
- Multiple Fan multi-point testing
 - Test protocol
 - Report template

For all attendees, we'll email you a link to these resources



OTHER RESEARCH

- Atlanta Better Buildings Challenge
 - Small commercial campus guides
- Third-party impact
- PPESCO
- EarthCraft Light Commercial Deep Energy



ADDITIONAL RESOURCES

EarthCraft Light Commercial Guidelines
ASHRAE Advanced Energy Design Guides
ASHRAE Advanced Energy Retrofit Guides
ASHRAE 189.1 – Green Building Standard
ASHRAE Indoor Air Quality Guide
ASHRAE Audit Guide
Core Performance Standard



ACBI RESEARCH PLAN



Benchmark

- Multi-point Blower Door Test
- Measure building pressure under normal operation
- Pressure test for presence/function of dampers
- Measure Intentional Ventilation Rates

Interactions

- Circuit level monitoring
- Outdoor and indoor zonal temperature and Humidity monitoring

Impact

- Calibrate detailed models
- Assess infiltration impact on energy consumption

WHAT'S NEXT?

- Spray foam & moisture accumulation
- IAQ & ventilation
- CAZ guidelines
- Packaging of tools & resources
- Deployment
- Refinement



ACKNOWLEDGEMENTS/CREDITS

- US Department of Energy
- Southface team
- ~50 buildings we have been able to test (and still counting)



RESEARCH HAS NO SHORT CUTS



Questions & Answers



CONTACT INFORMATION

Mike Barcik

mikeb@southface.org

404-604-3620



Bourke Reeve

breeve@southface.org

404-604-3619

